

AN ORDINANCE to amend 82-08 relating to construction, maintenance and acceptance of roads in the Madison County Road System.

BE IT ORDAINED BY THE FISCAL COURT OF MADISON COUNTY, COMMONWEALTH OF KENTUCKY:

1. Section 106a of Ordinance 82-08 shall be amended to read:  
106a. Blacktop shall have one layer of two inches of blacktop binder minimum and one layer of one inch of Class I blacktop minimum.
2. Section 204c of Ordinance 82-08 shall be amended to read:  
204c. Blacktop shall have one layer of two inches of blacktop binder minimum and one layer of one inch of Class I blacktop minimum.

NOW THEREFORE be it ordained the Madison County Fiscal Court establishes the aforementioned amendments to Ordinance 82-08 for County Road in Madison County.

MOTION TO ADOPT: Edward Chenault

SECONDED BY: Harold Botner

VOTE:	<u>FIRST READING</u>		<u>SECOND READING</u>	
	<u>YES</u>	<u>NO</u>	<u>YES</u>	<u>NO</u>
Harold Botner	<u>x</u>	<u>      </u>	<u>      </u>	<u>      </u>
Larry Combs	<u>      </u>	<u>x</u>	<u>      </u>	<u>      </u>
Farris Parks	<u>      </u>	<u>x</u>	<u>      </u>	<u>      </u>
Darrell Wells	<u>      </u>	<u>x</u>	<u>      </u>	<u>      </u>
Edward Chenault	<u>x</u>	<u>      </u>	<u>      </u>	<u>      </u>

Defeated

AN ORDINANCE to amend Ordinance 82-08 and adopt the following amendments.

BE IT ORDAINED BY THE FISCAL COURT OF MADISON COUNTY, COMMONWEALTH OF KENTUCKY:

1. Amend section 106 to read as follows:

- a. Three inches of blacktop
- b. Grade and level the sub-base to proper elevation to receive the base. Roll sub-base with a ten (10) ton roller with wheels topped  $\frac{1}{2}$  on each run, vibratory roller, sheep foot roller or rubber tire roller to meet correct compaction. NO top soil will be used for grade level sub-base.
- c. Provide a minimum of six (6) inches of crushed limestone base-six (6) inches minimum of dense grade or 610 crushed lime will be used in 3 inch layers and rolled as described in (b) above and allowed to set over (one winter) minimum to include twelve months.
- d. Blacktop shall be laid in two courses. First course shall be 2" of base and second course shall be 1" surface Class I Blacktop.
- e. Instead of the aforementioned method at the developer's option roads may be prepared in the following manner:
  - (1) Two inches of blacktop
  - (2) Grade and level the sub-base to proper elevation to receive the base. Roll sub-base with a ten (10) ton roller with wheels topped  $\frac{1}{2}$  on each run, vibratory roller, sheep foot roller or rubber tire roller to meet correct compaction. NO top soil will be used for grade level sub-base.
  - (3) Provide a minimum of eight (8) inches of crushed limestone base-six (6) inches minimum of dense grade or 610 crushed lime will be used in 4 inch layers and rolled as described in (b.) above and allowed to set over (one winter) minimum to include twelve months.
- f. Exceptions may be made by the fiscal court for streets constructed before January 1, 1980.

2. Amend section 204 to read as follows:

- a. Grade and level the sub-base to proper elevation to receive the base. Roll sub-base with a ten (10) ton roller with wheels topped  $\frac{1}{2}$  on each run, vibratory roller, sheep foot roller or rubber tire roller to meet correct compaction. NO top soil will be used for grade level sub-base.